



GMFZC.EX6226 Self-contained Automatic Extinguisher Units

[Page Bottom](#)

Self-contained Automatic Extinguisher Units

[See General Information for Self-contained Automatic Extinguisher Units](#)

INCONTROL SYSTEMS INC
75 Shields CT, Unit 4
Markham,, ON L3R 9T4 CANADA

EX6226

Fire extinguisher units containing HFC-227ea agent in accordance with the applicable requirements of UL 2166.

Model	Agent Capacity, kg	Max Protection Area, m ²	Max Hazard Length, m (any side)	Min/Max Ceiling Height, m	Rating	Date of Installation Manual (Date of Supplement)
SFS-06	2.7	8.80	4.60	0.46/3	A, B, C	Feb 13, 2015
SFM-07	3.2	8.80	4.60	0.46/3	A, B, C	Feb 13, 2015
SFM-09	4.1	8.80	4.60	0.46/3	A, B, C	Feb 13, 2015
SFM-12	5.5	8.80	4.60	0.46/3	A, B, C	Feb 13, 2015
SFL-15	6.8	8.65	4.60	0.46/3	A, B, C	Feb 13, 2015
SFL-20	9.1	8.65	4.60	0.46/3	A, B, C	Feb 13, 2015
SFL-24	10.9	8.65	4.60	0.46/3	A, B, C	Feb 13, 2015
SFX-31	13.6	9.06	4.60	1.14/3	A, B, C	Feb 13, 2015
SFX-36	15.9	9.06	4.60	1.14/3	A, B, C	Feb 13, 2015
SFX-42	19.1	9.06	4.60	1.14/3	A, B, C	Feb 13, 2015

These units are intended for the following:

- A. Protection of Class A, B and C fires
- B. Protection where a free-burning fire may be expected
- C. Storage and use within the temperature range of 0°C to 55°C
- D. Normal operating pressure of 12 bar at 21°C
- E. Intended for vertical/horizontal installation only for Models SFS, SFM and SFL
- F. Intended for vertical installation only for Model SFX
- G. To be designed and installed and maintained in accordance with the manufacturer's installation manual P/N 51-0100, Rev. 00, dated Feb 13, 2015

[Last Updated](#) on 2015-05-28

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

Copyright © 2015 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2015 Underwriters Laboratories of Canada Inc."

An independent organization working for a safer world with integrity, precision and knowledge.

