



GPHN.EX6226 Self-contained Automatic Extinguishing Units, Marine

[Page Bottom](#)

Self-contained Automatic Extinguishing Units, Marine

[See General Information for Self-contained Automatic Extinguishing Units, Marine](#)

INCONTROL SYSTEMS INC
75 Shields CT, Unit 4
Markham,, ON L3R 9T4 CANADA

EX6226

Fire extinguisher units containing HFC-227ea agent in accordance with the applicable requirements of UL 2166.

Model	Agent Capacity (lb)	Max Protection Area (ft ²)	Max Hazard Length (ft, any side)	Min/Max Ceiling Height (ft)	Rating	Date of Installation Manual (Date of Supplement)
SFS-06	6	94.7	15.1	1.5/10	A, B, C	Feb 13, 2015
SFM-07	7	94.7	15.1	1.5/10	A, B, C	Feb 13, 2015
SFM-09	9	94.7	15.1	1.5/10	A, B, C	Feb 13, 2015
SFM-12	12	94.7	15.1	1.5/10	A, B, C	Feb 13, 2015
SFL-15	15	93.1	15.1	1.5/10	A, B, C	Feb 13, 2015
SFL-20	20	93.1	15.1	1.5/10	A, B, C	Feb 13, 2015
SFL-24	24	93.1	15.1	1.5/10	A, B, C	Feb 13, 2015
SFX-31	31	97.51	15.1	3.75/10	A, B, C	Feb 13, 2015
SFX-36	36	97.51	15.1	3.75/10	A, B, C	Feb 13, 2015
SFX-42	42	97.51	15.1	3.75/10	A, B, C	Feb 13, 2015

These units are intended for the following:

- A. Protection of Class A, B and C fires
- B. Protection where a free-burning fire may be expected
- C. Storage and use within the temperature range of 32°F to 130°F (0°C to 55°C)
- D. Normal operating pressure of 175 psig (12 bar) at 70°F (21°C)
- E. Intended for vertical/horizontal installation only for Models SFS, SFM and SFL
- F. Intended for vertical installation only for Model SFX
- G. To be designed and installed and maintained in accordance with the manufacturer's installation manual P/N 51-0100, Rev. 00, dated Feb 13, 2015

[Last Updated](#) on 2015-05-28

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".