

Kidde Canada Inc.  
340 Four Valley Drive  
Vaughan, ON L4K 5Z1

Tel 905.695.6060 1.800.565.1976  
Fax 905.660.4670 1.877.660.4670  
www.kiddecanada.com



June 20, 2023



**PRODUCT BULLETIN**  
**PE-06-20-2023**

To all Badger Range Guard and Industry Guard Distributors

**Subject:** UCH Control Head Microswitch Availability

This bulletin is to inform you of an availability issue with **Microswitch Kit P/N B120047** used in the UCH Control Head. This microswitch is typically used for building fire alarm tie-in on Range Guard® and Industry Guard™ suppression systems and has screw-terminals to facilitate alarm supervision in accordance with NFPA 72 wiring requirements (i.e. wire splicing not allowed on alarm activation circuit). This microswitch has been discontinued by the manufacturer and we are in the process of qualifying a new replacement switch with approval agencies. We anticipate completing UL/ULC & FM approvals first, with CSA approval to follow. However, this process is taking longer than expected and we are in the process of determining an estimated completion date.

If an alternate solution is needed in the interim, an intermediate terminal block can be used to satisfy NFPA 72 alarm supervision wiring requirements using the P/N B120039 or P/N 87-120039-501 microswitch (with pigtail connector) in conjunction with a terminal block

(reference the example diagram below).

